



Telephone:0485-2995332  
email:-qcsdlktml@gmail.com

**KERALA WATER AUTHORITY**  
**QUALITY CONTROL SUB DISTRICT LAB, KOTHAMANGALAM-686691**  
(NABL,RECOGNIZED LABORATORY)

**WATER TEST REPORT**

Report Issue Date: 13.05.26

Report No:KTML/344/04/26

Customer Name &Address  AL AMAL PUBLIC SCHOOL NELLIKUZHI P.O KOTHAMANGALAM	Date of Receipt of Payment	30.04.26
	Date of Sample received	06.05.26
	Sample given by	Medical Officer FHC Cheruvattoor
	Sample Code	344/4/26
	Sample Name	DRINKING WATER
	Sample Condition	Good
	Source of Sample	WELL
	Sample Quantity	2 Litre
Test performing date: From : 07/05/2026 To 07/05/2026		

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.44
2	pH at 25° C		IS 3025 (Part 11)- 2022	6.5 to 8.5	6.66
3	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	5.97
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-2025	250	3.85
5	Electrical conductivity at 25°C	(micromhos/cm)	IS 3025 (Part 14)-2013(Reaffirmed 2019)		13
6	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	0.15
7	Nitrate (as NO3)	mg/L	IS 3025 (Part 34/Sec.1) 2023	45	2.6

Remarks:-

NB:-1) The result stated above related only to the sample(s) submitted for testing by the Customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

4) BDL= Below Detectable Limit

5) DL= Detectable Limit

End of Report



Analysed By  
TECHNICAL MANAGER  
SAVITHA P B

KWA/QCSDL/KTML/F- 26	Issue Date : 02.07.2021
Rev No:03	Rev Date : 26.04.2024
Page 1 of 1	



Telephone: 0485-2995332  
email: qcsdlktml@gmail.com

**KERALA WATER AUTHORITY**  
**QUALITY CONTROL SUB DISTRICT LAB, KOTHAMANGALAM-686691**  
**WATER TEST-BACTERIOLOGY REPORT**

Report No:KTML/344/04/26

Report Issue Date: 13.05.26

<b>Customer Name &amp;Address</b>		<b>Date of Receipt of Payment</b>	30.04.26	
<b>AL AMAL PUBLIC SCHOOL NELLIKUZHI P.O KOTHAMANGALAM</b>		<b>Date of Sample received</b>	06.05.26	
		<b>Sample given by</b>	Medical Officer FHC Cheruvattoor	
		<b>Sample Code</b>	344/4/26	
		<b>Sample Name</b>	DRINKING WATER	
		<b>Sample Condition</b>	Good	
		<b>Source of Sample</b>	WELL	
		<b>Sample Quantity</b>	250 ml	
<b>Test performing date: From : 06/05/2026 To 07/05/2026</b>				
<b>Sl. No.</b>	<b>Parameter</b>	<b>Acceptable Limit as per IS 10500-2012</b>	<b>Test Method</b>	<b>Result</b>
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016	ABSENT
2	E-Coli	Shall not be Detected/100ml	IS15185-2016	ABSENT

Remarks:-

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the Customer .  
2) The samples retain for 15 days from the end date of analysis  
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report



Analysed By

ATHIRA JANI

KWA/QCSDL/KTML/F-26	Issue Date : 02.07.2021
RevNo:03	Page 1 of 1
Rev.Date :-26.04.2024	